

LOCATION 1737 Linwood Rd.CITY ColumbiaBETWEEN Patricia

STREET &

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>3'</u>		<u>Tied over 155' of ext</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>		<u>2-10-94</u>	<u>3/4 Plastic to ext 2"</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>			<u>Plastic main</u>	

ENTERS: 1737BRANCHED INTO: 0TAP SIZE: 1/2PRESSURE 60 P.S.I. _____ INCHES W.C.

LOCATION

PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By EPMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1992DEPTH: 2 Ft. 6 In. LOCATION"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY