

LOCATION 1921 Linwood Rd. CITY BASTONIA
BETWEEN Archwood STREET & Hoyle St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>21'</u>	<u>7-16-94</u>	<u>Tied over 60' Existing</u>	
MAIN TO PROP. LINE					<u>3/4 CW</u>	
PROP. LINE TO BLDG.						

ENTERS: 1921 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 100 P.S.I. _____ INCHES W.C. LOCATION 8' E of Mary Lee St.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL
MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993
DEPTH: 3 Ft. 0 In. LOCATION 14' S of C of Linwood Rd.

"A" P/S READING _____ Plastic TOTAL ANODES 1# 1 17# _____ L.R. # _____

REMARKS: Boned Dresser, + installed 1# Anode.

Bare Main Replacement
Program

ORIGINAL installation 11/17/75



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser 100</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY

11-8-94
Riser-P.S. READING
.900
PER ROGER