

LOCATION 3580 LISMORE LN. CITY BASTON

BETWEEN Asbourne DR. STREET & Trake DR STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>114'</u>	<u>8-20-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>69'</u>			

ENTERS: 3580 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 149' S. of center l


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hunt & Sons

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 20' W. of center l LISMORE LN.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 430188

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		