

LOCATION 708 Littlejohn St CITY Gastonia

BETWEEN Poplar St STREET & W. Ayline Ave STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	8 1/2"	P	57'	11-26-02		
MAIN TO PROP LINE	8 1/2"	P	4'			
PROP LINE TO BLDG	8 1/2"	P	53'			

ENTERS 708 BRANCHED INTO

TAP SIZE: 1/2 PRESSURE 6.0 PSI _____ INCHES W C LOCATION 76' S. of center of Poplar St


PRESSURE TEST @ 100 PSI FOR 44 HRS BY S.H.

MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1991

DEPTH 3 FT 0 IN LOCATION 16' W. of center of Littlejohn St

"A" P/S READING P TOTAL ANODES 1# 2 17# 2 LR # 354262

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	