

LOCATION 815 Little John CITY Gastonia
BETWEEN Poplar STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>85'</u>	<u>3-27-00</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>35'</u>	<u>B.B</u>		
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>50'</u>			

ENTERS Same BRANCHED INTO

TAP SIZE. 1/2" PRESSURE 60# PSI INCHES W.C. LOCATION 16' South of

Little John St & 317' East of Poplar.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY B.B

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1991

DEPTH 3 FT 6 IN LOCATION 16' South of Little John

"A" P/S READING Plastic TOTAL ANODES 1# 17# L.R. #

REMARKS. New Service.

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>p. Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

