

LOCATION 3611 Little Mt. Rd. CITY Gastonia
BETWEEN Woodbury Lane STREET & Old York Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>60</u>		<u>9-26</u>	<u>94</u>
MAIN TO PROP. LINE	<u>1"</u>	<u>"</u>	<u>5'</u>		<u>62' of 3/4" cfw</u>	
PROP. LINE TO BLDG.	<u>1"</u>	<u>"</u>	<u>55'</u>			

ENTERS: 3611 Little Mt. Rd. BRANCHED INTO:
TAP SIZE: 1/2" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION E Side of house


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By GK

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1994

DEPTH: 3 Ft. _____ In. LOCATION S. side of Little Mt. Rd.

"A" P/S READING 5 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>5</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY