

LOCATION 4802 LITTLE MTN. RD. CITY Gastonia

BETWEEN Benton Ave STREET & Gayle Ave STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>145'</u>	<u>8-18-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>90'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>53'</u>			

ENTERS: 4802 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 131' NE. of center of
LITTLE MTN RD.


PRESSURE TEST: @ 100 PSI FOR 4 HRS. BY S. Hutchins

MAIN-SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1986

DEPTH: 2 FT. 0 IN. LOCATION 109' NW of center of Benton Ave

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 542364

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY