

LOCATION 2006 Little Mt. Rd CITY Gastonia

BETWEEN Gayle STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED <u>9</u>	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>121'</u>		<u>12-13-00</u>	
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>40'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>81'</u>			

ENTERS 5006 BRANCHED INTO 0

TAP SIZE 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY EB

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED \_\_\_\_\_

DEPTH 2 FT 6 IN LOCATION

"A" P/S READING Plastic TOTAL ANODES 1# — 17# — LR # \_\_\_\_\_

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	