

LOCATION 5007 Little Mt. Rd. CITY GASTONIA
BETWEEN Forbes Rd. STREET & Bayle Ave. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>88'</u>	<u>10-21-97</u>	<u>Retired 100'</u>	<u>Existing 3/4" C.W.</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>20'</u>		<u>Pipe under</u>	<u>New Addition</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>68'</u>		<u>to house. System Enhancement</u>	

ENTERS: 5007 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 600 PSI _____ INCHES W.C. LOCATION 645' E of Cof Bayle Ave.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL
MAIN-SIZE _____ C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED _____
DEPTH: _____ FT. _____ IN. LOCATION 15' S of Cof Little Mt. Rd.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY