

LOCATION 5208 LITTLE MOUNTAIN RD.CITY GASTONIABETWEEN FORBES RD.STREET & ROBINSON RD.

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	$\frac{3}{4}$	PL.	128'	10-27-98		
MAIN TO PROP. LINE	$\frac{3}{4}$	PL.	32'	10-27-98		
PROP. LINE TO BLDG.	$\frac{3}{4}$	PL.	96'	10-27-98		

ENTERS: 5208 LITTLE MOUNTAIN RD.

BRANCHED INTO:

TAP SIZE: $\frac{3}{4}$ PRESSURE 60 PSI _____ INCHES W.C. LOCATION 268' EAST OF C. OF FORBES RD.PRESSURE TEST: @ 100 PSI FOR $\frac{1}{4}$ HRS BY R. RutterMAIN-SIZE 4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1998DEPTH: 3 FT. IN. LOCATION 14' SOUTH OF C. OF LITTLE MOUNTAIN RD."A" P/S READING PL. TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY